



## TECHNICAL BULLETIN WMX-Series Installation Variances

**Introduction.** Due to the significant number of flow meter applications with adverse installation conditions, Seametrics, Inc. contracted to have a series of tests performed to determine the effects of adverse installation configurations on the accuracy of the WMX-Series flow meter. After reviewing the results of field and lab tests, including tests performed at California Polytechnic State University (Cal Poly), we have concluded that traditional straight pipe requirements can be reduced or even eliminated without causing significant deterioration in this meter's accuracy.

**90° Elbow Test (Figure 1).** In the first test, performed in the Seametrics lab, a WMX-Series flow meter was connected to a 90° elbow with no straight pipe on either the upstream or downstream sides. Testing demonstrated approximately 1% deviation in the meter's accuracy.



**Reduced Pipe and Butterfly Valve (Figure 2).** In the second test, performed at Cal Poly, a 10" WMX was mounted on a turbine pump, downstream of an 8"x10" cast-iron concentric adapter, and immediately downstream of a butterfly valve.




This configuration introduces spiral action caused by the pump, velocity distortion caused by the  $90^{\circ}$  elbow in the pump discharge head, jetting caused by the 8"x 10" concentric adapter, and turbulence caused by the throttled butterfly valve. There was also a wafer butterfly check valve connected directly to the downstream side of the meter. This test configuration was designed to represent the worst possible conditions. Until the butterfly valve was closed more than 50%, the accuracy of the meter deviated less than 1.5% from the control meter.


Page 1

**Close Coupled Butterfly Valve (Figure 3).** In the third test, also performed at Cal Poly, a 4" WMX was mounted with less than two pipe diameters of straight pipe on the upstream side of a butterfly valve and zero pipe diameters from a diaphragm pressure regulating valve on the downstream side.


Two reference full bore meters were installed over 20 pipe diameters downstream of the WMX, with at least 20 diameters of straight pipe both upstream and downstream on each meter. A series of flow tests were performed on all three meters. With the butterfly valve wide open, all the meters read 401 GPM. The butterfly valve was progressively closed, and at each step, all three meters read the same down to 12 GPM, the low flow cutoff for the 4" WMX meter. This configuration showed no deterioration in the accuracy of the meter.



**Pump Discharge Flange and Check Valve (Figures 4a and 4b).** In the fourth test, performed in the field in Nebraska, a WMX-Series meter was mounted in two different configurations. In the first, the WMX was mounted directly to the pump discharge head, with a spring-loaded swing check valve directly downstream.



In the second configuration, a spring-loaded swing check valve was mounted directly to the pump discharge with the WMX mounted directly to the check valve.



After a series of tests on these installation configurations, variations in meter accuracy were determined to be less than 1% of the flow rate. Analysis of this data along with other compiled data indicates that direct coupling to a pump discharge or spring-loaded swing check valve seems to have no significant impact on the accuracy of the WMX meter.

**Conclusion.** It is always optimal to install a flow meter with the traditional recommended straight pipe standards to achieve the highest level of accuracy. Nevertheless, the WMX-Series flow meter performed within  $\pm$ 2% accuracy in applications with no straight pipe upstream or downstream of a butterfly valve, 90° elbow, pump discharge, or spring-loaded swing check valve.

NOTE: It is always recommended that chemigation injection be performed downstream of a WMX flow meter.

NOTE: This document does not supercede state and local health code or installation requirements. All applications of this meter must comply with applicable regulations.

